



November 11, 2024

Mr. Philip Henderson
Head Custodian
Bradley Beach Board of Education
515 Brinley Avenue
Bradley Beach, New Jersey 07720

Re: Summary Report
Lead in Water Testing and Analysis

Facility: Bradley Beach Elementary School
515 Brinley Avenue
Bradley Beach, New Jersey

EC Project #: 24310-01

Environmental Connection, Inc., (EC) was contracted by the Bradley Beach Board of Education (BBBOE) to collect and provide laboratory analysis of water samples from the Bradley Beach Elementary School, located at 515 Brinley Avenue in Bradley Beach, New Jersey. Sampling was completed on October 11, 2024, between the hours of 6:00 AM and 7:00 AM.

Samples were collected from 16 locations, as follows:

- Spigot in Basement Custodial Storage Room (Point of Entry Sample)
- Water Chiller Fountain in Basement Hallway by Copy Room
- Water Chiller Fountain in Basement Hallway by Room 29
- Sink Faucet in Nurse's Office (Left)
- Sink Faucet in Nurse's Office (Right)
- Sink Faucet in Kitchen (Dishwash)
- Sink Faucet in Kitchen (Handwash)
- Water Chiller Fountain in Basement Hallway by Cafeteria
- Filtered Bottle Fill Station in Cafeteria (Basement)
- Water Chiller Fountain in First Floor Hallway by Main Office
- Water Chiller Fountain in First Floor Hallway by Room 10
- Water Chiller Fountain in Second Floor Hallway by Room 15
- Sink Faucet in Second Floor Teacher's Lounge
- Sink Faucet in Room 22
- Sink Faucet in Room 21
- Sink Faucet in Room 20

Samples were collected in sterile 250 milliliter bottles, pre-treated with nitric acid solution (HNO₃). The sampling technician utilized new vinyl gloves at each testing location. At each location, a "first draw" sample was collected prior to any known usage of the fixture,



immediately after which the fixture was flushed for 30 seconds and a second draw sample was collected. Note: Flush draw samples were not collected from outlets incorporated with holding tanks. The samples were hand delivered to EMSL Analytical, Inc., (IATL) of Cinnaminson, New Jersey. EMSL is certified by the State of New Jersey, Department of Environmental Protection (NJDEP), for drinking water analysis.

Analysis was completed in accordance with United States Environmental Protection Agency (USEPA) Method 200.8. The USEPA and NJDEP Action Level of 15 parts per billion (ppb) or micrograms per liter (µg/L) was used to determine if further testing and/or remediation is warranted. Where levels above 15 ppb or µg/L were detected, analysis of the second draw sample was performed, in accordance with USEPA protocol.

Results of analysis are summarized in Table 1 below:

Table 1 – Lead in Water Sampling Results Bradley Beach Elementary School 515 Brinley Avenue, Bradley Beach, New Jersey 07720				
Sample Location	Parameter	Results of 1st Draw Sample (ppb)	Results of 2nd Draw Sample (ppb)	USEPA & NJDEP Action Level (ppb)
Spigot in Basement Custodial Storage Room (Near Point of Entry)	Lead in Water	34.5	N/A	15
Water Chiller Fountain in Basement Hall by Copy Room	Lead in Water	<1.00	N/A	15
Water Chiller Fountain in Basement Hall by Room 29	Lead in Water	<1.00	N/A	15
Sink Faucet in Nurses Office (Left)	Lead in Water	<1.00	N/A	15
Sink Faucet in Nurses Office (Right)	Lead in Water	<1.00	N/A	15
Sink Faucet in Kitchen (Dish Wash)	Lead in Water	<1.00	N/A	15
Sink Faucet in Kitchen (Hand Wash)	Lead in Water	<1.00	N/A	15
Water Chiller Fountain in Basement Hall by Cafeteria	Lead in Water	<1.00	N/A	15
Filtered Bottle Fill Station in Basement Cafeteria	Lead in Water	<1.00	N/A	15
Water Chiller Fountain in First Floor Hall by Main Office	Lead in Water	<1.00	N/A	15
Water Chiller Fountain in First Floor Hall by Room 10	Lead in Water	<1.00	N/A	15
Water Chiller Fountain in Second Floor Hall by Room 15	Lead in Water	<1.00	N/A	15
Sink Faucet in Second Floor Teachers' Lounge	Lead in Water	<1.00	N/A	15
Sink Faucet in Room 22 (Second Floor)	Lead in Water	<1.00	N/A	15



Table 1 – Lead in Water Sampling Results Bradley Beach Elementary School 515 Brinley Avenue, Bradley Beach, New Jersey 07720				
Sample Location	Parameter	Results of 1 st Draw Sample (ppb)	Results of 2 nd Draw Sample (ppb)	USEPA & NJDEP Action Level (ppb)
Sink Faucet in Room 21 (Second Floor)	Lead in Water	<1.00	N/A	15
Sink Faucet in Room 20 (Second Floor)	Lead in Water	<1.00	N/A	15

One (1) test location, the Basement Custodial Storage Spigot, exhibited a lead concentration above the USEPA and NJDEP Action Level of 15 parts per billion (ppb). The fixture in the Basement Custodial Storage is not a drinking or cooking outlet and therefore does not require remediation. Based on the results of analysis, EC recommends inspecting the service line that enters the building for lead components. If found, lead plumbing materials should be replaced. All other locations exhibited lead concentrations below the aforementioned threshold and therefore do not require remediation.

Should you have any questions or require additional information, please contact the undersigned at your convenience.

Respectfully Submitted:
ENVIRONMENTAL CONNECTION, INC.

Mike Moore
Project Manager

Attachment 1: Analytical Report and Chain of Custody for Lead in Water Sampling

ATTACHMENT I

Analytical Report and Chain of Custody for Lead in Water Sampling

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433486
LIMS Reference ID: AC33486
EMSL Customer ID: ENVI65

Attention: Mike Moore
 Environmental Connection, Inc. [ENVI65]
 120 North Warren Street
 Trenton, NJ 08608
 (609) 392-4200
 mmoore@vtihq.com

Project Name: Bradley Beach Board of Education
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/11/2024 12:20
Reported: 10/18/2024 16:25

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: 01- Basement Custodial Storage Point of Entry **Lims Reference ID:** AC33486-01 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:16:00

Metals

Lead	34.5		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:37	PL	EPA 200.8 (DA)/EPA 200.8
------	------	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 02- Basement Hall By Copy Room Water Chiller Fountain **Lims Reference ID:** AC33486-03 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:23:00

Metals

Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:39	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 03- Basement Hall By Art Room 29 Water Chiller Fountain **Lims Reference ID:** AC33486-04 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:25:00

Metals

Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:41	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 04- Basement Nurse Nurses Suite Sink Faucet (L) **Lims Reference ID:** AC33486-05 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:28:00

Metals

Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:43	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 05- Basement Nurse - Nurses Suite Sink Faucet (R) **Lims Reference ID:** AC33486-07 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:31:00

Metals

Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:49	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 06- Basement Kitchen - Kitchen Sink Faucet (Dish Wash) **Lims Reference ID:** AC33486-09 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:33:00

Metals

Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:51	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 07- Basement Kitchen - Kitchen Sink Faucet (Hand Wash) **Lims Reference ID:** AC33486-11 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:37:00

Metals

Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:57	PL	EPA 200.8 (DA)/EPA 200.8
------	----	--	---	------	------	----------------	----------------	----	--------------------------

Sample: 08- Basement Hall By Cafeteria Water Chiller Fountain **Lims Reference ID:** AC33486-13 **Matrix:** Drinking Water **Sampled:** 10/11/24 06:39:00

Metals

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433486
LIMS Reference ID: AC33486
EMSL Customer ID: ENVI65

Attention: Mike Moore
 Environmental Connection, Inc. [ENVI65]
 120 North Warren Street
 Trenton, NJ 08608
 (609) 392-4200
 mmoore@vtihq.com

Project Name: Bradley Beach Board of Education
Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/11/2024 12:20
Reported: 10/18/2024 16:25

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 08- Basement Hall By Cafeteria Water Chiller Fountain (Continued)									
			Lims Reference ID: AC33486-13 Matrix: Drinking Water				Sampled: 10/11/24 06:39:00		
Metals (Continued)									
Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 18:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 09- Basement Cafeteria - Cafeteria Bottle Fill Station (Post Filler)									
			Lims Reference ID: AC33486-14 Matrix: Drinking Water				Sampled: 10/11/24 06:40:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 19:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 10- First Floor Hall By Main Office Water Chiller Fountain									
			Lims Reference ID: AC33486-15 Matrix: Drinking Water				Sampled: 10/11/24 06:42:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 19:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11- First Floor Hall By Room 10 Water Chiller Fountain									
			Lims Reference ID: AC33486-16 Matrix: Drinking Water				Sampled: 10/11/24 06:44:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 19:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12- Second Floor Hall By Room 15 Water Chiller Fountain									
			Lims Reference ID: AC33486-17 Matrix: Drinking Water				Sampled: 10/11/24 06:50:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 19:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13- Second Floor Teachers Lounge Sink Faucet									
			Lims Reference ID: AC33486-18 Matrix: Drinking Water				Sampled: 10/11/24 06:52:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 15:28	10/16/24 19:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14- Second Floor Room 22 Sml Faucet									
			Lims Reference ID: AC33486-20 Matrix: Drinking Water				Sampled: 10/11/24 06:58:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 17:20	10/16/24 17:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15- Second Floor Room 21 Sml Faucet									
			Lims Reference ID: AC33486-22 Matrix: Drinking Water				Sampled: 10/11/24 07:02:00		
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 17:20	10/16/24 17:14	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433486
LIMS Reference ID: AC33486
EMSL Customer ID: ENVI65

Attention: Mike Moore
 Environmental Connection, Inc. [ENVI65]
 120 North Warren Street
 Trenton, NJ 08608
 (609) 392-4200
 mmoore@vtihq.com

Project Name: Bradley Beach Board of Education

Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/11/2024 12:20
Reported: 10/18/2024 16:25

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 16- Second Floor Room 20 Sml Faucet			Lims Reference ID: AC33486-24			Matrix: Drinking Water		Sampled: 10/11/24 07:05:00	
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 17:20	10/16/24 17:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17- Blank			Lims Reference ID: AC33486-26			Matrix: Drinking Water		Sampled: 10/11/24 00:00:00	
Metals									
Lead	ND		1	1.00	µg/L	10/15/24 17:20	10/16/24 17:18	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:856-786-5974
 EMSL-CIN-01

EMSL Order ID: 012433486
LIMS Reference ID: AC33486
EMSL Customer ID: ENVI65

Attention: Mike Moore
 Environmental Connection, Inc. [ENVI65]
 120 North Warren Street
 Trenton, NJ 08608
 (609) 392-4200
 mmoore@vtihq.com

Project Name: Bradley Beach Board of Education

Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/11/2024 12:20
Reported: 10/18/2024 16:25

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2024
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	01/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:856-786-5974
EMSL-CIN-01

EMSL Order ID: 012433486
LIMS Reference ID: AC33486
EMSL Customer ID: ENVI65

Attention: Mike Moore
Environmental Connection, Inc. [ENVI65]
120 North Warren Street
Trenton, NJ 08608
(609) 392-4200
mmoore@vtihq.com

Project Name: Bradley Beach Board of Education

Customer PO:
EMSL Sales Rep: Josh Silverman
Received: 10/11/2024 12:20
Reported: 10/18/2024 16:25

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



AC 33486

ENVIRONMENTAL CONNECTION INC

A Vertical Technologies Corporation

Potable Water Sampling for Lead Concentration Sample Collection Form

Client Information

Name: Bradley Beach Board of Education
Address: 515 Brinley Avenue, Bradley Beach NJ
Client Rep.: Mr. Philip Henderson

School Project Information

Building Id:				
Building No./Name: Bradley Beach Elementary School				
Building Address: 515 Brinley Avenue, Bradley Beach NJ				
Contact Name & Numbers:				
(0)Yr. Built	(1)Yr. 1 st Add.:	(2)Yr. 2 nd Add.:	(3)Yr. 1 st Mod.:	(4)Yr. 2 nd Mod.:

Inspector(s): M.Moore/J.Martin

Date of Sampling: 10/11/24

Sample Data

Sample Description ID (ID Must Match Container Label)							Outlet Information			Results		
Sample #	Floor	Functional Space Code	IN/By	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates	MFS/Model Serial #	0 Seconds	30 Seconds	Time of Collection (24 Hr)	Lead Conc. (ppb)
01	Basement			Custodial Storage	POE	POE	Point of Entry		x		6:16	
F-01	Basement			Custodial Storage	POE	POE	Point of Entry		x		6:16	
02	Basement	Hall	By	Copy Rm	WL	WL	Water Cooler Fountain		x		6:23	
03	Basement	Hall	By	Art Room 2P	WL	WL	Water Cooler Fountain		x		6:25	
04	Basement	Nurse		Nurses Suite	SF	SF	Sink Faucet (L)		x		6:28	
F-04	Basement	Nurse		Nurses Suite	SF	SF	Sink Faucet (L)		<		6:29	
05	Basement	Nurse		Nurses Suite	SF	SF	Sink Faucet (R)		<		6:31	
F-05	Basement	Nurse		Nurses Suite	SF	SF	Sink Faucet (R)		<		6:32	
06	Basement	Kitchen		Kitchen	SF	SF	Sink Faucet (Dish Wash)		<		6:33	
F-06	Basement	Kitchen		Kitchen	SF	SF	Sink Faucet (Dish Wash)		<		6:34	

All Containers are pre-cleaned/pre-certified 250 ml plastic bottles preserved w/ HNO3 @ pH<2 by field or to be preserved by lab

Chain of Custody

Relinquished By:	Received By:	Date/Time:
<i>NA</i>	<i>JM 1155</i>	<i>10/11/24</i>
	<i>Angie Onnell</i>	<i>10/11/24 2:05pm</i>
	<i>J. P. Ornelas</i>	<i>10/11/24 12:20pm</i>

Method of Shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other:

Instructions to the Laboratory

<input checked="" type="checkbox"/> Analyze "30 seconds" sample(s) ONLY when Initial sample exceeds 15 ppb <input type="checkbox"/> Analyze both initial and follow-up samples <input type="checkbox"/> Other: Follow QAPP	Lab: EMSL 200 Route 130 Cinnaminson, NJ 08077	Report Results To: Mike Moore <input type="checkbox"/> Phone (609) 392-4200 <input checked="" type="checkbox"/> Email: mmoore@vtihq.com <input type="checkbox"/> Fax: (609) 392-1216
--	---	---

Comments: Provide electronic and hard copy of Sample Chain of Custody with sample results and final analytical report.

Cancel Flashes.

TURN AROUND TIME REQUESTED: 1 WEEK

1 of 3 Rec'd Res.



AC 33486

ENVIRONMENTAL CONNECTION INC

A Vertical Technologies Corporation

Potable Water Sampling for Lead Concentration Sample Collection Form

Client Information

Name: Bradley Beach Board of Education
Address: 515 Brinley Avenue, Bradley Beach NJ
Client Rep.: Mr. Philip Henderson

School Project Information

Building Id:				
Building No./Name: Bradley Beach Elementary School				
Building Address: 515 Brinley Avenue, Bradley Beach NJ				
Contact Name & Numbers:				
(0)Yr. Built	(1)Yr. 1 st Add.:	(2)Yr. 2 nd Add.:	(3)Yr. 1 st Mod.:	(4)Yr. 2 nd Mod.:

Inspector(s): M.Moore/J.Martin

Date of Sampling: 10/11/24

Sample Data

Sample Description ID (ID Must Match Container Label)							Outlet Information			Results		
Sample #	Floor	Functional Space Code	IN/By	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates	MFS/Model Serial #	0 Seconds	30 Seconds	Time of Collection (24 Hr)	Lead Conc. (ppb)
07	Basement	Kitchen		Kitchen		SP	Sink Faucet (Hand Wash)		x		6:37	
P-07	Basement	Kitchen		Kitchen		SP	Sink Faucet (Hand Wash)			*	6:38	
08	Basement	Mail Box		Closet		WC	Water Chiller Fountain		x		6:39	
09	Basement	Closet		Closet		WC	Bottle Fill Station (post Filter)		x		6:40	
10	First Floor	Hall By		Main office		WC	Water Chiller Fountain		x		6:42	
11	First Floor	Hall By		Room 10		WC	Water Chiller Fountain		x		6:44	
12	Second Floor	Hall By		Room 15		WC	Water Chiller Fountain		x		6:50	
13	Second Floor	Hall By		Room 15		WC	Water Chiller Fountain		x		6:52	
13	Second Floor			Teachers Lounge		SP	Sink Faucet		x		6:52	
P-13	Second Floor			Teachers Lounge		SP	Sink Faucet		x		6:53	

All Containers are pre-cleaned/pre-certified 250 ml plastic bottles preserved w/ HNO3 @ pH<2 by field or to be preserved by lab

Chain of Custody

Relinquished By:	Received By:	Date/Time:
<i>MA</i>	<i>gm 1155</i>	10/11/24
	<i>James O'Neil</i>	10/11/24 12:05 PM
	<i>J. Moore</i>	10/11/24 6:20 PM

Method of Shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other:

Instructions to the Laboratory

<input checked="" type="checkbox"/> Analyze "30 seconds" sample(s) ONLY when Initial sample exceeds 15 ppb <input type="checkbox"/> Analyze both initial and follow-up samples <input type="checkbox"/> Other: Follow QAPP	Lab: EMSL 200 Route 130 Cinnaminson, NJ 08077	Report Results To: Mike Moore <input type="checkbox"/> Phone (609) 392-4200 <input checked="" type="checkbox"/> Email: mmoore@vtihq.com <input type="checkbox"/> Fax: (609) 392-1216
--	---	---

Comments: Provide electronic and hard copy of Sample Chain of Custody with sample results and final analytical report.

TURN AROUND TIME REQUESTED: 1 WEEK

2 of 3



AC 33484

ENVIRONMENTAL CONNECTION INC

A Vertical Technologies Corporation

Potable Water Sampling for Lead Concentration Sample Collection Form

Client Information

Name: Bradley Beach Board of Education
Address: 515 Brinley Avenue, Bradley Beach NJ
Client Rep.: Mr. Philip Henderson

School Project Information

Building Id:				
Building No./Name: Bradley Beach Elementary School				
Building Address: 515 Brinley Avenue, Bradley Beach NJ				
Contact Name & Numbers:				
(0)Yr. Built	(1)Yr. 1 st Add.:	(2)Yr. 2 nd Add.:	(3)Yr. 1 st Mod.:	(4)Yr. 2 nd Mod.:

Inspector(s): M.Moore/J.Martin

Date of Sampling: 10/11/24

Sample Data

Sample Description ID (ID Must Match Container Label)							Outlet Information			Results		
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates	MFS/Model Serial #	0 Seconds	30 Seconds	Time of Collection (24 Hr)	Lead Conc. (ppb)
14	Second Floor		Room	22	SF		Smk Faucet				6:58	
F14	Second Floor		Room	22	SF		Smk Faucet			X	6:57	
15	Second Floor		Room	21	SF		Smk Faucet			L	7:02	
F-15	Second Floor		Room	21	SF		Smk Faucet			X	7:03	
16	Second Floor		Room	20	SF		Smk Faucet			L	7:05	
F-16	Second Floor		Room	20	SF		Smk Faucet			X	7:06	
17	Blome		Blome				Blome					

All Containers are pre-cleaned/pre-certified 250 ml plastic bottles preserved w/ HNO3 @ pH<2 by field or to be preserved by lab

Chain of Custody

Relinquished By:	Received By:	Date/Time:
<i>[Signature]</i>	<i>[Signature]</i> 11:55	10/11/24
	<i>[Signature]</i> WE	10/11/24 12:55 pm
	<i>[Signature]</i>	10/11/24 12:20 pm

Method of Shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other:

Instructions to the Laboratory

<input checked="" type="checkbox"/> Analyze "30 seconds" sample(s) ONLY when Initial sample exceeds 15 ppb <input type="checkbox"/> Analyze both initial and follow-up samples <input type="checkbox"/> Other: Follow QAPP	Lab: EMSL 200 Route 130 Cinnaminson, NJ 08077	Report Results To: Mike Moore <input type="checkbox"/> Phone (609) 392-4200 <input checked="" type="checkbox"/> Email: mmoore@vtihq.com <input type="checkbox"/> Fax: (609) 392-1216
---	---	---

Comments: Provide electronic and hard copy of Sample Chain of Custody with sample results and final analytical report.

TURN AROUND TIME REQUESTED: 1 WEEK

3 of 3